



About UL

Businesses

Solutions

Newsroom

Media Contacts

Press Releases

Public Notices

Story Ideas

UL Press Kit - Background

UL Press Kit - Fact Sheet

Home > Newsroom

UL warns of counterfeit UL Mark on fire sprinkler (Release 13PN-06)

Northbrook, IL - January 31, 2013 -The following is a notification from UL to distributors, contractors, fire departments, regulatory agencies, and authorities having jurisdiction that the fire sprinkler identified below bears a counterfeit UL Mark for the United States and Canada. The sprinkler was not manufactured by Nanjing Fire Protection Technology Co Ltd and the thermo bulb was not manufactured by Job, GmbH.

The Fire Sprinkler has not been evaluated by UL to the appropriate Standards for Safety and it is unknown if the fire sprinkler complies with any safety requirements.

Name of Product: Fire Sprinkler, Model NX005

Identification: On the product: The counterfeit fire sprinkler can be identified by "NX" and "C-I" marking on the wrench boss of the fire sprinkler frame and may have model NX005 on the sprinkler deflector. Sprinklers manufactured by Nanjing Fire Protection Technology Co Ltd that are authorized to bear the UL Mark do not have "NX" and "C-I" marking on the wrench boss.

Photographs of the product with counterfeit UL Mark:



UL is a global independent safety science company offering expertise across five key strategic businesses: Product Safety,

About UL

History

Leadership

Careers

Newsroom

Businesses

Product Safety

Environment

Life & Health

Verification Services

Tools

MyHome

Online Certifications Directory

Certification Marks

UL Collaborative Standards Development System